

1 Name of PWS: Lincoln Water System		2 Point of Ap: West Treatment Plant		3 Operator <i>Guo S Lee</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%	6 Avail Fluor. Ion - 79%	7 Month/Year	July	2021
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	34.460	742.74	0.49	0.4	0.89
2	na	31.130	670.97	0.49	0.4	0.89
3	na	33.375	719.36	0.49	0.4	0.89
4	na	32.999	711.25	0.49	0.4	0.89
5	na	27.594	594.76	0.49	0.4	0.89
6	na	35.239	759.53	0.49	0.4	0.89
7	na	36.797	793.12	0.49	0.4	0.89
8	na	32.416	698.69	0.49	0.4	0.89
9	na	29.117	627.58	0.49	0.4	0.89
10	na	26.718	575.87	0.49	0.4	0.89
11	na	21.716	448.26	0.47	0.4	0.87
12	na	26.644	521.68	0.45	0.4	0.85
13	na	32.077	690.69	0.49	0.4	0.89
14	na	29.543	632.10	0.49	0.4	0.89
15	na	22.073	458.25	0.47	0.4	0.87
16	na	19.870	427.72	0.49	0.4	0.89
17	na	18.956	407.68	0.49	0.4	0.89
18	na	18.860	405.98	0.49	0.4	0.89
19	na	29.691	638.87	0.49	0.4	0.89
20	na	31.500	678.13	0.49	0.4	0.89
21	na	34.793	748.35	0.49	0.4	0.89
22	na	32.099	662.59	0.47	0.4	0.87
23	na	31.534	617.42	0.45	0.4	0.85
24	na	39.339	847.06	0.49	0.4	0.89
25	na	36.660	784.38	0.49	0.4	0.89
26	na	23.029	495.77	0.49	0.4	0.89
27	na	25.805	555.03	0.49	0.4	0.89
28	na	27.517	539.71	0.45	0.4	0.85
29	na	31.627	680.87	0.49	0.4	0.89
30	na	29.511	634.74	0.49	0.4	0.89
31	na	24.103	472.75	0.45	0.4	0.85
Totals				Average	0.4	0.88

RETURN TO:

HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: *Glenn P. Lee*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year July 2021

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	25.245	513.90	0.46	0.4	0.86	
2	na	28.997	583.90	0.46	0.4	0.86	
3	na	29.162	607.40	0.47	0.4	0.87	
4	na	28.302	613.30	0.49	0.4	0.89	
5	na	27.248	554.60	0.46	0.4	0.86	
6	na	28.745	601.10	0.48	0.4	0.88	
7	na	27.543	580.70	0.48	0.4	0.88	
8	na	25.978	547.40	0.48	0.4	0.88	
9	na	27.234	552.70	0.46	0.4	0.86	
10	na	23.799	524.40	0.50	0.4	0.90	
11	na	20.900	428.40	0.47	0.4	0.87	
12	na	24.735	510.10	0.47	0.4	0.87	
13	na	26.964	551.70	0.47	0.4	0.87	
14	na	29.170	577.20	0.45	0.4	0.85	
15	na	24.954	519.90	0.47	0.4	0.87	
16	na	25.925	513.10	0.45	0.4	0.85	
17	na	25.309	511.10	0.46	0.4	0.86	
18	na	28.323	585.60	0.47	0.4	0.87	
19	na	28.334	504.50	0.40	0.4	0.80	
20	na	28.405	583.40	0.47	0.4	0.87	
21	na	30.183	469.40	0.35	0.4	0.75	
22	na	29.105	623.00	0.49	0.4	0.89	
23	na	29.456	601.10	0.46	0.4	0.86	
24	na	29.964	614.10	0.47	0.4	0.87	
25	na	30.064	625.00	0.47	0.4	0.87	
26	na	36.909	737.60	0.45	0.4	0.85	
27	na	39.289	830.00	0.48	0.4	0.88	
28	na	35.638	841.60	0.54	0.4	0.94	
29	na	39.434	856.30	0.49	0.4	0.89	
30	na	38.880	830.60	0.49	0.4	0.89	
31	na	34.016	773.40	0.52	0.4	0.92	
Totals					Average	0.4	0.87

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: West Treatment Plant		3 Operator: <i>Ernie J. ...</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%		6 Avail Fluor. Ion - 79%		
7 Month/Year		August		2021		
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	21.620	535.60	0.56	0.4	0.96
2	na	20.180	432.30	0.49	0.4	0.89
3	na	24.402	544.10	0.51	0.4	0.91
4	na	22.904	502.30	0.50	0.4	0.90
5	na	22.541	480.60	0.48	0.4	0.88
6	na	25.654	572.70	0.51	0.4	0.91
7	na	24.499	484.10	0.45	0.4	0.85
8	na	14.083	300.30	0.48	0.4	0.88
9	na	21.895	489.20	0.51	0.4	0.91
10	na	24.243	499.90	0.47	0.4	0.87
11	na	24.837	533.30	0.49	0.4	0.89
12	na	23.159	514.70	0.51	0.4	0.91
13	na	24.408	510.90	0.48	0.4	0.88
14	na	26.898	590.90	0.50	0.4	0.90
15	na	24.731	545.60	0.50	0.4	0.90
16	na	24.012	525.40	0.50	0.4	0.90
17	na	27.370	596.00	0.50	0.4	0.90
18	na	25.430	554.00	0.50	0.4	0.90
19	na	24.564	530.40	0.49	0.4	0.89
20	na	26.202	611.60	0.53	0.4	0.93
21	na	21.288	433.40	0.46	0.4	0.86
22	na	21.387	445.90	0.47	0.4	0.87
23	na	31.007	677.70	0.50	0.4	0.90
24	na	27.598	601.40	0.50	0.4	0.90
25	na	26.721	584.40	0.50	0.4	0.90
26	na	25.195	550.40	0.50	0.4	0.90
27	na	29.705	661.40	0.51	0.4	0.91
28	na	32.032	652.90	0.46	0.4	0.86
29	na	27.094	593.70	0.50	0.4	0.90
30	na	23.161	507.60	0.50	0.4	0.90
31	na	21.496	466.90	0.49	0.4	0.89
Totals				Average	0.4	0.89

RETURN TO:

HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: East Treatment Plant		3 Operator: <i>Eric Lee</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%	6 Avail Fluor. Ion - 79%	7 Month/Year September		2021
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	24.030	493.38	0.47	0.4	0.87	
2	na	26.175	511.36	0.44	0.4	0.84	
3	na	21.679	452.12	0.47	0.4	0.87	
4	na	21.493	445.90	0.47	0.4	0.87	
5	na	22.182	444.70	0.46	0.4	0.86	
6	na	22.281	424.10	0.43	0.4	0.83	
7	na	26.285	527.10	0.46	0.4	0.86	
8	na	28.228	560.80	0.45	0.4	0.85	
9	na	27.162	561.60	0.47	0.4	0.87	
10	na	27.377	562.10	0.47	0.4	0.87	
11	na	29.023	567.00	0.44	0.4	0.84	
12	na	27.082	564.80	0.47	0.4	0.87	
13	na	24.096	490.00	0.46	0.4	0.86	
14	na	27.080	573.30	0.48	0.4	0.88	
15	na	26.065	507.30	0.44	0.4	0.84	
16	na	20.499	438.90	0.49	0.4	0.89	
17	na	16.991	368.30	0.49	0.4	0.89	
18	na	18.340	376.60	0.47	0.4	0.87	
19	na	19.623	415.60	0.48	0.4	0.88	
20	na	20.660	418.90	0.46	0.4	0.86	
21	na	23.310	483.20	0.47	0.4	0.87	
22	na	21.073	441.80	0.48	0.4	0.88	
23	na	21.800	449.80	0.47	0.4	0.87	
24	na	20.529	418.60	0.46	0.4	0.86	
25	na	20.712	429.30	0.47	0.4	0.87	
26	na	20.558	432.40	0.48	0.4	0.88	
27	na	20.547	423.20	0.47	0.4	0.87	
28	na	21.320	439.80	0.47	0.4	0.87	
29	na	20.011	412.10	0.47	0.4	0.87	
30	na	18.652	383.40	0.47	0.4	0.87	
Totals					Average	0.4	0.87

RETURN TO:


HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: West Treatment Plant		3 Operator: <i>Eric Cole</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%	6 Avail Fluor. Ion - 79%	7 Month/Year September 2021		
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	23.177	525.40	0.52	0.4	0.92	
2	na	23.664	528.90	0.51	0.4	0.91	
3	na	21.013	468.00	0.51	0.4	0.91	
4	na	19.191	410.80	0.49	0.4	0.89	
5	na	19.132	411.30	0.49	0.4	0.89	
6	na	21.472	424.90	0.45	0.4	0.85	
7	na	26.265	576.60	0.50	0.4	0.90	
8	na	24.948	545.80	0.50	0.4	0.90	
9	na	30.069	666.60	0.50	0.4	0.90	
10	na	30.208	660.40	0.50	0.4	0.90	
11	na	34.264	768.90	0.51	0.4	0.91	
12	na	32.492	717.50	0.50	0.4	0.90	
13	na	20.461	464.90	0.52	0.4	0.92	
14	na	27.277	548.00	0.46	0.4	0.86	
15	na	34.567	717.63	0.47	0.4	0.87	
16	na	38.191	822.09	0.49	0.4	0.89	
17	na	39.088	840.66	0.49	0.4	0.89	
18	na	37.678	811.05	0.49	0.4	0.89	
19	na	35.709	768.37	0.49	0.4	0.89	
20	na	35.485	763.92	0.49	0.4	0.89	
21	na	37.368	803.73	0.49	0.4	0.89	
22	na	32.841	677.91	0.47	0.4	0.87	
23	na	34.538	676.24	0.45	0.4	0.85	
24	na	34.291	738.36	0.49	0.4	0.89	
25	na	34.620	740.73	0.49	0.4	0.89	
26	na	33.138	713.40	0.49	0.4	0.89	
27	na	40.605	873.35	0.49	0.4	0.89	
28	na	41.354	811.11	0.45	0.4	0.85	
29	na	33.378	718.56	0.49	0.4	0.89	
30	na	27.890	599.87	0.49	0.4	0.89	
Totals					Average	0.4	0.89

RETURN TO:

HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: 

4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year: October 2021


8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	18.428	378.70	0.47	0.4	0.87	
2	na	18.771	385.90	0.47	0.4	0.87	
3	na	18.962	389.80	0.47	0.4	0.87	
4	na	18.989	390.30	0.47	0.4	0.87	
5	na	18.960	389.70	0.47	0.4	0.87	
6	na	18.603	382.40	0.47	0.4	0.87	
7	na	18.459	379.40	0.47	0.4	0.87	
8	na	20.348	417.90	0.47	0.4	0.87	
9	na	23.317	479.60	0.47	0.4	0.87	
10	na	22.850	469.90	0.47	0.4	0.87	
11	na	22.422	461.10	0.47	0.4	0.87	
12	na	20.201	415.80	0.47	0.4	0.87	
13	na	15.833	325.30	0.47	0.4	0.87	
14	na	16.486	338.30	0.47	0.4	0.87	
15	na	18.855	387.80	0.47	0.4	0.87	
16	na	18.879	388.00	0.47	0.4	0.87	
17	na	19.203	394.60	0.47	0.4	0.87	
18	na	19.512	401.10	0.47	0.4	0.87	
19	na	18.922	388.90	0.47	0.4	0.87	
20	na	19.982	410.80	0.47	0.4	0.87	
21	na	19.934	409.90	0.47	0.4	0.87	
22	na	18.782	385.90	0.47	0.4	0.87	
23	na	18.986	390.30	0.47	0.4	0.87	
24	na	17.792	365.90	0.47	0.4	0.87	
25	na	16.112	330.90	0.47	0.4	0.87	
26	na	16.159	331.90	0.47	0.4	0.87	
27	na	16.105	330.90	0.47	0.4	0.87	
28	na	16.256	333.90	0.47	0.4	0.87	
29	na	8.638	178.58	0.47	0.4	0.87	
30	na	0.000	0.00		0.4		
31	na	0.000	0.00		0.4		
Totals					Average	0.4	0.87

East Plant shutdown
10/29/2021 E. Lee

RETURN TO: HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator:



4 Fluor. Chem. Used: H2SIF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year:

October 2021

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	27.973	608.80	0.49	0.4	0.89	
2	na	33.106	721.10	0.50	0.4	0.90	
3	na	32.932	716.90	0.49	0.4	0.89	
4	na	34.848	758.30	0.49	0.4	0.89	
5	na	32.891	715.30	0.49	0.4	0.89	
6	na	34.208	743.10	0.49	0.4	0.89	
7	na	34.790	755.50	0.49	0.4	0.89	
8	na	34.784	755.00	0.49	0.4	0.89	
9	na	37.183	807.50	0.49	0.4	0.89	
10	na	28.490	620.80	0.50	0.4	0.90	
11	na	28.345	617.30	0.50	0.4	0.90	
12	na	26.424	575.20	0.49	0.4	0.89	
13	na	20.630	452.50	0.50	0.4	0.90	
14	na	21.867	472.90	0.49	0.4	0.89	
15	na	20.692	442.20	0.49	0.4	0.89	
16	na	19.912	425.30	0.49	0.4	0.89	
17	na	20.154	430.40	0.49	0.4	0.89	
18	na	22.338	477.50	0.49	0.4	0.89	
19	na	22.962	490.50	0.49	0.4	0.89	
20	na	26.850	573.90	0.49	0.4	0.89	
21	na	21.271	455.00	0.49	0.4	0.89	
22	na	19.589	418.10	0.49	0.4	0.89	
23	na	19.960	427.00	0.49	0.4	0.89	
24	na	13.256	282.80	0.48	0.4	0.88	
25	na	14.357	306.10	0.48	0.4	0.88	
26	na	13.114	278.90	0.48	0.4	0.88	
27	na	11.320	241.20	0.48	0.4	0.88	
28	na	11.448	244.00	0.48	0.4	0.88	
29	na	19.411	413.31	0.48	0.4	0.88	
30	na	36.896	785.42	0.48	0.4	0.88	
31	na	36.522	777.26	0.48	0.4	0.88	
Totals					Average	0.4	0.89

RETURN TO: HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: East Treatment Plant		3 Operator: <i>[Signature]</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%		6 Avail Fluor. Ion - 79%		
				7 Month/Year November 2021		
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	calculated fluoride values mg/L

1	na	0.000	0.00		0.4		
2	na	0.000	0.00		0.4		
3	na	15.127	310.96	0.47	0.4	0.87	
4	na	38.966	801.30	0.47	0.4	0.87	
5	na	30.807	630.60	0.47	0.4	0.87	
6	na	28.336	583.10	0.47	0.4	0.87	
7	na	28.163	579.40	0.47	0.4	0.87	
8	na	27.638	564.30	0.46	0.4	0.86	
9	na	28.352	583.00	0.47	0.4	0.87	
10	na	28.121	578.80	0.47	0.4	0.87	
11	na	26.707	549.30	0.47	0.4	0.87	
12	na	27.405	563.90	0.47	0.4	0.87	
13	na	27.391	563.50	0.47	0.4	0.87	
14	na	28.092	577.80	0.47	0.4	0.87	
15	na	24.275	498.60	0.47	0.4	0.87	
16	na	24.013	493.60	0.47	0.4	0.87	
17	na	21.920	443.53	0.47	0.4	0.87	
18	na	3.861	79.37	0.47	0.4	0.87	
19	na	0.000	0.00		0.4		
20	na	0.000	0.00		0.4		
21	na	0.000	0.00		0.4		
22	na	0.000	0.00		0.4		
23	na	0.000	0.00		0.4		
24	na	0.000	0.00		0.4		
25	na	0.000	0.00		0.4		
26	na	0.000	0.00		0.4		
27	na	0.000	0.00		0.4		
28	na	0.000	0.00		0.4		
29	na	0.000	0.00		0.4		
30	na	0.000	0.00		0.4		
Totals					Average	0.4	0.87

East Plant shutdown 11-1-21 through 11-2-21 for electrical maintenance project
 East Plant taken off-line 11-19-21 E. Lee

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year November 2021

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	calculated fluoride values mg/L

1	na	27.322	561.47	0.47	0.4	0.87	
2	na	25.652	527.36	0.47	0.4	0.87	
3	na	21.271	437.27	0.47	0.4	0.87	
4	na	0.000	0.00		0.4		
5	na	0.000	0.00		0.4		
6	na	0.000	0.00		0.4		
7	na	0.000	0.00		0.4		
8	na	0.000	0.00		0.4		
9	na	0.000	0.00		0.4		
10	na	0.000	0.00		0.4		
11	na	0.000	0.00		0.4		
12	na	0.000	0.00		0.4		
13	na	0.000	0.00		0.4		
14	na	0.000	0.00		0.4		
15	na	0.000	0.00		0.4		
16	na	0.000	0.00		0.4		
17	na	2.644	54.33	0.47	0.4	0.87	
18	na	24.512	503.88	0.47	0.4	0.87	
19	na	29.387	603.99	0.47	0.4	0.87	
20	na	26.575	546.34	0.47	0.4	0.87	
21	na	24.982	513.70	0.47	0.4	0.87	
22	na	25.876	531.66	0.47	0.4	0.87	
23	na	25.677	527.85	0.47	0.4	0.87	
24	na	28.489	585.89	0.47	0.4	0.87	
25	na	28.575	586.86	0.47	0.4	0.87	
26	na	25.163	516.84	0.47	0.4	0.87	
27	na	25.695	527.94	0.47	0.4	0.87	
28	na	26.906	552.65	0.47	0.4	0.87	
29	na	24.895	514.68	0.47	0.4	0.87	
30	na	27.460	567.71	0.47	0.4	0.87	
Totals					Average	0.4	0.87

Treatment Plant taken off-line 11-4-21 RETURN TO:
 through 11-16-21 E. Lee

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year: December 2021

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	27.984	597.10	0.49	0.4	0.89	
2	na	29.604	631.40	0.48	0.4	0.88	
3	na	30.212	644.90	0.49	0.4	0.89	
4	na	29.824	636.50	0.49	0.4	0.89	
5	na	24.832	530.10	0.49	0.4	0.89	
6	na	24.492	522.30	0.48	0.4	0.88	
7	na	24.844	529.70	0.48	0.4	0.88	
8	na	26.384	562.70	0.48	0.4	0.88	
9	na	27.766	592.40	0.49	0.4	0.89	
10	na	28.969	618.20	0.49	0.4	0.89	
11	na	28.238	602.80	0.49	0.4	0.89	
12	na	26.053	555.80	0.48	0.4	0.88	
13	na	26.054	555.80	0.48	0.4	0.88	
14	na	29.160	621.80	0.48	0.4	0.88	
15	na	27.881	595.60	0.49	0.4	0.89	
16	na	26.929	574.80	0.49	0.4	0.89	
17	na	25.481	498.50	0.44	0.4	0.84	
18	na	28.703	524.30	0.42	0.4	0.82	
19	na	28.158	512.20	0.41	0.4	0.81	
20	na	27.102	543.30	0.46	0.4	0.86	
21	na	25.503	544.40	0.49	0.4	0.89	
22	na	25.645	547.40	0.49	0.4	0.89	
23	na	25.460	543.50	0.49	0.4	0.89	
24	na	27.179	579.90	0.49	0.4	0.89	
25	na	24.192	516.80	0.49	0.4	0.89	
26	na	23.106	493.00	0.49	0.4	0.89	
27	na	23.263	496.30	0.49	0.4	0.89	
28	na	24.257	517.40	0.48	0.4	0.88	
29	na	23.860	509.40	0.49	0.4	0.89	
30	na	28.622	610.50	0.48	0.4	0.88	
31	na	30.497	651.80	0.49	0.4	0.89	
Totals					Average	0.4	0.88

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year December 2021

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	0.000			0.4		
2	na	0.000			0.4		
3	na	0.000			0.4		
4	na	0.000			0.4		
5	na	0.000			0.4		
6	na	0.000			0.4		
7	na	0.000			0.4		
8	na	0.000			0.4		
9	na	0.000			0.4		
10	na	0.000			0.4		
11	na	0.000			0.4		
12	na	0.000			0.4		
13	na	0.000			0.4		
14	na	0.000			0.4		
15	na	0.000			0.4		
16	na	0.000			0.4		
17	na	0.000			0.4		
18	na	0.000			0.4		
19	na	0.000			0.4		
20	na	0.000			0.4		
21	na	0.000			0.4		
22	na	0.000			0.4		
23	na	0.000			0.4		
24	na	0.000			0.4		
25	na	0.000			0.4		
26	na	0.000			0.4		
27	na	0.000			0.4		
28	na	0.000			0.4		
29	na	0.000			0.4		
30	na	0.000			0.4		
31	na	0.000			0.4		
Totals					Average	0.4	

East Plant Off-line
All of December E. Lee 1-4-22

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: *E. Lee*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year January 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	0.000			0.4	
2	na	0.000			0.4	
3	na	0.000			0.4	
4	na	0.000			0.4	
5	na	0.000			0.4	
6	na	0.000			0.4	
7	na	0.000			0.4	
8	na	0.000			0.4	
9	na	0.000			0.4	
10	na	0.000			0.4	
11	na	0.000			0.4	
12	na	0.000			0.4	
13	na	0.000			0.4	
14	na	0.000			0.4	
15	na	0.000			0.4	
16	na	0.000			0.4	
17	na	0.000			0.4	
18	na	0.000			0.4	
19	na	0.000			0.4	
20	na	0.000			0.4	
21	na	0.000			0.4	
22	na	0.000			0.4	
23	na	0.000			0.4	
24	na	0.000			0.4	
25	na	0.000			0.4	
26	na	0.000			0.4	
27	na	0.000			0.4	
28	na	0.000			0.4	
29	na	0.000			0.4	
30	na	0.000			0.4	
31	na	0.000			0.4	
Totals					Average	0.4

East Plant Out of Service
 all of January E.Lee 2/1/22

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year February 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	28.426	641.40	0.51	0.4	0.91	
2	na	28.920	653.90	0.51	0.4	0.91	
3	na	26.581	596.31	0.51	0.4	0.91	
4	na	25.848	584.50	0.51	0.4	0.91	
5	na	27.138	613.80	0.51	0.4	0.91	
6	na	27.133	613.60	0.51	0.4	0.91	
7	na	26.354	596.00	0.51	0.4	0.91	
8	na	28.670	648.30	0.51	0.4	0.91	
9	na	27.818	629.30	0.51	0.4	0.91	
10	na	28.535	645.30	0.51	0.4	0.91	
11	na	27.992	636.30	0.52	0.4	0.92	
12	na	25.828	584.00	0.51	0.4	0.91	
13	na	25.943	586.60	0.51	0.4	0.91	
14	na	25.980	587.40	0.51	0.4	0.91	
15	na	26.377	596.40	0.51	0.4	0.91	
16	na	27.796	628.50	0.51	0.4	0.91	
17	na	28.089	635.20	0.51	0.4	0.91	
18	na	29.258	661.60	0.51	0.4	0.91	
19	na	29.902	676.60	0.51	0.4	0.91	
20	na	26.959	609.60	0.51	0.4	0.91	
21	na	27.652	625.30	0.51	0.4	0.91	
22	na	27.638	625.10	0.51	0.4	0.91	
23	na	25.725	581.80	0.51	0.4	0.91	
24	na	26.705	603.60	0.51	0.4	0.91	
25	na	28.303	640.10	0.51	0.4	0.91	
26	na	25.776	583.00	0.51	0.4	0.91	
27	na	26.570	600.70	0.51	0.4	0.91	
28	na	27.942	631.80	0.51	0.4	0.91	
Totals					Average	0.4	0.91

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year February 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	0.000	0.00		0.4	
2	na	0.000	0.00		0.4	
3	na	0.000	0.00		0.4	
4	na	0.000	0.00		0.4	
5	na	0.000	0.00		0.4	
6	na	0.000	0.00		0.4	
7	na	0.000	0.00		0.4	
8	na	0.000	0.00		0.4	
9	na	0.000	0.00		0.4	
10	na	0.000	0.00		0.4	
11	na	0.000	0.00		0.4	
12	na	0.000	0.00		0.4	
13	na	0.000	0.00		0.4	
14	na	0.000	0.00		0.4	
15	na	0.000	0.00		0.4	
16	na	0.000	0.00		0.4	
17	na	0.000	0.00		0.4	
18	na	0.000	0.00		0.4	
19	na	0.000	0.00		0.4	
20	na	0.000	0.00		0.4	
21	na	0.000	0.00		0.4	
22	na	0.000	0.00		0.4	
23	na	0.000	0.00		0.4	
24	na	0.000	0.00		0.4	
25	na	0.000	0.00		0.4	
26	na	0.000	0.00		0.4	
27	na	0.000	0.00		0.4	
28	na	0.000	0.00		0.4	
Totals					Average	0.4

East Plant off-line
 all of February 2022 E. Lee

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: East Treatment Plant		3 Operator: <i>[Signature]</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%		6 Avail Fluor. Ion - 79%		
7 Month/Year		March		2022		
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Treated Water Tests mg/L

1	na	0.000	0.00		0.4	
2	na	0.000	0.00		0.4	
3	na	0.000	0.00		0.4	
4	na	0.000	0.00		0.4	
5	na	0.000	0.00		0.4	
6	na	0.000	0.00		0.4	
7	na	0.000	0.00		0.4	
8	na	0.000	0.00		0.4	
9	na	0.000	0.00		0.4	
10	na	0.000	0.00		0.4	
11	na	0.000	0.00		0.4	
12	na	0.000	0.00		0.4	
13	na	0.000	0.00		0.4	
14	na	0.000	0.00		0.4	
15	na	0.000	0.00		0.4	
16	na	4.642	90.10	0.44	0.4	0.84
17	na	18.093	386.70	0.49	0.4	0.89
18	na	18.066	386.20	0.49	0.4	0.89
19	na	18.074	386.30	0.49	0.4	0.89
20	na	18.076	386.30	0.49	0.4	0.89
21	na	18.070	386.30	0.49	0.4	0.89
22	na	17.681	377.90	0.49	0.4	0.89
23	na	17.506	374.10	0.49	0.4	0.89
24	na	17.509	374.20	0.49	0.4	0.89
25	na	17.584	375.80	0.49	0.4	0.89
26	na	17.406	371.90	0.49	0.4	0.89
27	na	17.641	377.00	0.49	0.4	0.89
28	na	17.577	375.60	0.49	0.4	0.89
29	na	17.920	382.90	0.49	0.4	0.89
30	na	17.665	377.60	0.49	0.4	0.89
31	na	24.025	514.20	0.49	0.4	0.89
Totals				Average	0.4	0.88

East Plant started up afternoon of
3/16/22 E. Lee

RETURN TO:

HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SIF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year March 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Treated Water Tests mg/L

1	na	32.437	733.40	0.51	0.4	0.91
2	na	37.460	847.50	0.51	0.4	0.91
3	na	33.782	763.70	0.51	0.4	0.91
4	na	31.267	707.40	0.51	0.4	0.91
5	na	26.687	603.60	0.51	0.4	0.91
6	na	25.649	579.90	0.51	0.4	0.91
7	na	25.742	582.10	0.51	0.4	0.91
8	na	27.866	629.90	0.51	0.4	0.91
9	na	28.711	649.40	0.51	0.4	0.91
10	na	27.534	619.30	0.51	0.4	0.91
11	na	26.550	600.70	0.51	0.4	0.91
12	na	25.817	584.20	0.51	0.4	0.91
13	na	24.732	559.50	0.51	0.4	0.91
14	na	25.798	583.80	0.51	0.4	0.91
15	na	27.273	616.90	0.51	0.4	0.91
16	na	25.558	577.90	0.51	0.4	0.91
17	na	10.970	247.60	0.51	0.4	0.91
18	na	10.880	245.30	0.51	0.4	0.91
19	na	9.836	221.80	0.51	0.4	0.91
20	na	10.050	226.40	0.51	0.4	0.91
21	na	10.170	229.30	0.51	0.4	0.91
22	na	10.176	229.10	0.51	0.4	0.91
23	na	10.291	230.80	0.51	0.4	0.91
24	na	10.142	228.50	0.51	0.4	0.91
25	na	10.765	242.70	0.51	0.4	0.91
26	na	10.075	226.80	0.51	0.4	0.91
27	na	10.239	230.50	0.51	0.4	0.91
28	na	10.267	231.10	0.51	0.4	0.91
29	na	11.092	249.40	0.51	0.4	0.91
30	na	12.410	279.90	0.51	0.4	0.91
31	na	7.361	122.10	0.38	0.4	0.78
Totals				Average	0.4	0.91

West Plant shutdown morning of
 3/31/22 E. Lee

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: West Treatment Plant		3 Operator: <i>E. Lee</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%	6 Avail Fluor. Ion - 79%	7 Month/Year	April 2022	
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated fluoride values mg/L

1	na	0.000	0.00		0.4		
2	na	0.000	0.00		0.4		
3	na	0.000	0.00		0.4		
4	na	0.000	0.00		0.4		
5	na	0.000	0.00		0.4		
6	na	0.000	0.00		0.4		
7	na	0.000	0.00		0.4		
8	na	0.000	0.00		0.4		
9	na	0.000	0.00		0.4		
10	na	0.000	0.00		0.4		
11	na	0.000	0.00		0.4		
12	na	0.000	0.00		0.4		
13	na	0.000	0.00		0.4		
14	na	0.000	0.00		0.4		
15	na	0.000	0.00		0.4		
16	na	0.000	0.00		0.4		
17	na	0.000	0.00		0.4		
18	na	0.000	0.00		0.4		
19	na	0.000	0.00		0.4		
20	na	0.000	0.00		0.4		
21	na	0.000	0.00		0.4		
22	na	0.000	0.00		0.4		
23	na	0.000	0.00		0.4		
24	na	0.000	0.00		0.4		
25	na	0.000	0.00		0.4		
26	na	0.000	0.00		0.4		
27	na	0.000	0.00		0.4		
28	na	0.000	0.00		0.4		
29	na	5.377	91.30	0.39	0.4	0.79	
30	na	13.287	261.30	0.45	0.4	0.85	
Totals					Average	0.4	0.82

West plant started up afternoon of 4/29/22 E. Lee

RETURN TO:

HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year April 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated fluoride values mg/L

1	na	30.378	649.90	0.49	0.4	0.89	
2	na	29.033	621.20	0.49	0.4	0.89	
3	na	29.226	625.30	0.49	0.4	0.89	
4	na	29.436	629.60	0.49	0.4	0.89	
5	na	30.215	646.40	0.49	0.4	0.89	
6	na	30.019	642.30	0.49	0.4	0.89	
7	na	29.792	637.40	0.49	0.4	0.89	
8	na	27.760	593.80	0.49	0.4	0.89	
9	na	29.817	637.70	0.49	0.4	0.89	
10	na	34.707	742.50	0.49	0.4	0.89	
11	na	38.531	824.40	0.49	0.4	0.89	
12	na	39.060	836.40	0.49	0.4	0.89	
13	na	27.468	587.80	0.49	0.4	0.89	
14	na	27.774	594.00	0.49	0.4	0.89	
15	na	28.174	602.70	0.49	0.4	0.89	
16	na	29.410	629.10	0.49	0.4	0.89	
17	na	30.048	642.90	0.49	0.4	0.89	
18	na	28.361	606.80	0.49	0.4	0.89	
19	na	30.624	654.80	0.49	0.4	0.89	
20	na	34.069	729.10	0.49	0.4	0.89	
21	na	33.016	706.40	0.49	0.4	0.89	
22	na	33.335	713.20	0.49	0.4	0.89	
23	na	35.237	753.80	0.49	0.4	0.89	
24	na	38.770	829.60	0.49	0.4	0.89	
25	na	42.443	909.40	0.49	0.4	0.89	
26	na	43.174	923.90	0.49	0.4	0.89	
27	na	43.277	926.30	0.49	0.4	0.89	
28	na	44.689	956.60	0.49	0.4	0.89	
29	na	34.456	737.20	0.49	0.4	0.89	
30	na	15.509	330.60	0.48	0.4	0.88	
Totals					Average	0.4	0.89

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: West Treatment Plant		3 Operator: <i>Eric L Zee</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%	6 Avail Fluor. Ion - 79%	7 Month/Year	May 2022	
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	13.788	274.30	0.51	0.4	0.91
2	na	21.086	455.50	0.51	0.4	0.91
3	na	28.542	644.30	0.51	0.4	0.91
4	na	29.183	658.70	0.51	0.4	0.91
5	na	30.441	686.90	0.51	0.4	0.91
6	na	32.791	735.62	0.51	0.4	0.91
7	na	35.957	806.64	0.51	0.4	0.91
8	na	35.472	795.76	0.51	0.4	0.91
9	na	35.273	791.30	0.51	0.4	0.91
10	na	23.811	534.17	0.51	0.4	0.91
11	na	22.500	500.90	0.51	0.4	0.91
12	na	28.719	649.20	0.51	0.4	0.91
13	na	16.864	381.30	0.51	0.4	0.91
14	na	16.788	379.40	0.51	0.4	0.91
15	na	17.231	389.50	0.51	0.4	0.91
16	na	18.344	414.60	0.51	0.4	0.91
17	na	19.332	438.10	0.51	0.4	0.91
18	na	18.080	407.80	0.51	0.4	0.91
19	na	17.661	399.30	0.51	0.4	0.91
20	na	21.715	491.80	0.51	0.4	0.91
21	na	28.683	648.80	0.51	0.4	0.91
22	na	27.665	625.90	0.51	0.4	0.91
23	na	28.233	638.80	0.51	0.4	0.91
24	na	23.481	534.50	0.51	0.4	0.91
25	na	19.001	429.30	0.51	0.4	0.91
26	na	17.890	404.40	0.51	0.4	0.91
27	na	24.120	546.30	0.51	0.4	0.91
28	na	25.182	569.70	0.51	0.4	0.91
29	na	24.528	554.90	0.51	0.4	0.91
30	na	22.174	501.60	0.51	0.4	0.91
31	na	32.088	725.60	0.51	0.4	0.91
Totals				Average	0.4	0.91

RETURN TO:

HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: East Treatment Plant		3 Operator: <i>E. Lee</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%	6 Avail Fluor. Ion - 79%	7 Month/Year	May 2022	
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	15.662	334.40	0.49	0.4	0.89
2	na	10.057	215.30	0.49	0.4	0.89
3	na	0.000	0.00		0.4	
4	na	0.000	0.00		0.4	
5	na	0.000	0.00		0.4	
6	na	0.000	0.00		0.4	
7	na	0.000	0.00		0.4	
8	na	0.000	0.00		0.4	
9	na	0.000	0.00		0.4	
10	na	13.885	299.27	0.49	0.4	0.89
11	na	26.477	566.30	0.49	0.4	0.89
12	na	29.026	620.70	0.49	0.4	0.89
13	na	26.881	575.30	0.49	0.4	0.89
14	na	23.582	504.30	0.49	0.4	0.89
15	na	23.601	504.70	0.49	0.4	0.89
16	na	23.569	504.00	0.49	0.4	0.89
17	na	23.631	505.30	0.49	0.4	0.89
18	na	23.144	494.90	0.49	0.4	0.89
19	na	21.789	466.20	0.49	0.4	0.89
20	na	20.706	442.20	0.49	0.4	0.89
21	na	14.145	302.10	0.49	0.4	0.89
22	na	14.272	304.70	0.49	0.4	0.89
23	na	14.593	311.70	0.49	0.4	0.89
24	na	14.593	311.70	0.49	0.4	0.89
25	na	14.285	305.00	0.49	0.4	0.89
26	na	14.423	308.10	0.49	0.4	0.89
27	na	14.687	313.60	0.49	0.4	0.89
28	na	14.849	317.10	0.49	0.4	0.89
29	na	15.046	321.40	0.49	0.4	0.89
30	na	13.833	295.40	0.49	0.4	0.89
31	na	13.835	295.40	0.49	0.4	0.89
Totals				Average	0.4	0.89

East plant Out of Service May 3rd through May 9th E. Lee

RETURN TO:

HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: *Greg C. Jase*
 4 Fluor. Chem. Used: H2SIF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year June 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	16.031	343.10	0.49	0.4	0.89	
2	na	17.299	369.60	0.49	0.4	0.89	
3	na	17.692	377.10	0.48	0.4	0.88	
4	na	17.252	369.30	0.49	0.4	0.89	
5	na	16.931	361.10	0.48	0.4	0.88	
6	na	16.019	342.40	0.49	0.4	0.89	
7	na	17.891	383.10	0.49	0.4	0.89	
8	na	18.346	391.40	0.49	0.4	0.89	
9	na	14.446	308.50	0.49	0.4	0.89	
10	na	14.488	309.40	0.49	0.4	0.89	
11	na	15.574	332.60	0.49	0.4	0.89	
12	na	16.920	361.50	0.49	0.4	0.89	
13	na	21.300	455.40	0.49	0.4	0.89	
14	na	26.770	572.70	0.49	0.4	0.89	
15	na	23.258	498.10	0.49	0.4	0.89	
16	na	18.423	393.70	0.49	0.4	0.89	
17	na	17.663	377.40	0.49	0.4	0.89	
18	na	18.957	404.60	0.49	0.4	0.89	
19	na	21.168	452.90	0.49	0.4	0.89	
20	na	25.943	554.40	0.49	0.4	0.89	
21	na	25.041	547.90	0.50	0.4	0.90	
22	na	26.807	573.80	0.49	0.4	0.89	
23	na	24.241	518.70	0.49	0.4	0.89	
24	na	26.041	556.80	0.49	0.4	0.89	
25	na	23.219	497.30	0.49	0.4	0.89	
26	na	22.591	483.50	0.49	0.4	0.89	
27	na	24.108	515.20	0.49	0.4	0.89	
28	na	28.429	608.40	0.49	0.4	0.89	
29	na	28.315	606.70	0.49	0.4	0.89	
30	na	28.278	605.10	0.49	0.4	0.89	
Totals					Average	0.4	0.89

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *Perkins*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year July 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	31.780	690.50	0.49	0.4	0.89	
2	na	29.521	642.70	0.49	0.4	0.89	
3	na	29.250	635.10	0.49	0.4	0.89	
4	na	29.665	646.20	0.50	0.4	0.90	
5	na	28.392	607.90	0.49	0.4	0.89	
6	na	32.913	715.40	0.49	0.4	0.89	
7	na	30.948	672.60	0.49	0.4	0.89	
8	na	27.703	603.10	0.49	0.4	0.89	
9	na	27.629	602.40	0.50	0.4	0.90	
10	na	28.175	614.40	0.50	0.4	0.90	
11	na	31.354	680.10	0.49	0.4	0.89	
12	na	29.511	641.10	0.49	0.4	0.89	
13	na	30.849	670.50	0.49	0.4	0.89	
14	na	38.755	840.30	0.49	0.4	0.89	
15	na	39.589	858.80	0.49	0.4	0.89	
16	na	44.415	964.10	0.49	0.4	0.89	
17	na	33.173	720.40	0.49	0.4	0.89	
18	na	30.837	670.40	0.49	0.4	0.89	
19	na	37.483	813.10	0.49	0.4	0.89	
20	na	38.912	844.10	0.49	0.4	0.89	
21	na	30.650	666.60	0.49	0.4	0.89	
22	na	30.949	670.60	0.49	0.4	0.89	
23	na	29.290	636.10	0.49	0.4	0.89	
24	na	27.010	587.50	0.49	0.4	0.89	
25	na	27.979	609.60	0.50	0.4	0.90	
26	na	25.453	555.10	0.50	0.4	0.90	
27	na	23.092	502.50	0.49	0.4	0.89	
28	na	22.004	480.40	0.50	0.4	0.90	
29	na	29.588	642.30	0.49	0.4	0.89	
30	na	34.389	747.30	0.49	0.4	0.89	
31	na	33.859	735.30	0.49	0.4	0.89	
Totals					Average	0.4	0.89

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *Greg Carter*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year July 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	31.780	690.50	0.49	0.4	0.89
2	na	29.521	642.70	0.49	0.4	0.89
3	na	29.250	635.10	0.49	0.4	0.89
4	na	29.665	646.20	0.50	0.4	0.90
5	na	28.392	607.90	0.49	0.4	0.89
6	na	32.913	715.40	0.49	0.4	0.89
7	na	30.948	672.60	0.49	0.4	0.89
8	na	27.703	603.10	0.49	0.4	0.89
9	na	27.629	602.40	0.50	0.4	0.90
10	na	28.175	614.40	0.50	0.4	0.90
11	na	31.354	680.10	0.49	0.4	0.89
12	na	29.511	641.10	0.49	0.4	0.89
13	na	30.849	670.50	0.49	0.4	0.89
14	na	38.755	840.30	0.49	0.4	0.89
15	na	39.589	858.80	0.49	0.4	0.89
16	na	44.415	964.10	0.49	0.4	0.89
17	na	33.173	720.40	0.49	0.4	0.89
18	na	30.837	670.40	0.49	0.4	0.89
19	na	37.483	813.10	0.49	0.4	0.89
20	na	38.912	844.10	0.49	0.4	0.89
21	na	30.650	666.60	0.49	0.4	0.89
22	na	30.949	670.60	0.49	0.4	0.89
23	na	29.290	636.10	0.49	0.4	0.89
24	na	27.010	587.50	0.49	0.4	0.89
25	na	27.979	609.60	0.50	0.4	0.90
26	na	25.453	555.10	0.50	0.4	0.90
27	na	23.092	502.50	0.49	0.4	0.89
28	na	22.004	480.40	0.50	0.4	0.90
29	na	29.588	642.30	0.49	0.4	0.89
30	na	34.389	747.30	0.49	0.4	0.89
31	na	33.859	735.30	0.49	0.4	0.89

Totals	Average	0.4	0.89
--------	---------	-----	------

RETURN TO: HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: *Eric Lee*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year August 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	32.507	695.30	0.49	0.4	0.89
2	na	35.008	749.60	0.49	0.4	0.89
3	na	34.937	748.10	0.49	0.4	0.89
4	na	34.116	730.60	0.49	0.4	0.89
5	na	31.002	663.70	0.49	0.4	0.89
6	na	32.510	695.90	0.49	0.4	0.89
7	na	32.497	695.80	0.49	0.4	0.89
8	na	31.648	677.80	0.49	0.4	0.89
9	na	31.692	678.30	0.49	0.4	0.89
10	na	31.570	676.00	0.49	0.4	0.89
11	na	31.571	675.60	0.49	0.4	0.89
12	na	31.839	681.60	0.49	0.4	0.89
13	na	30.913	661.90	0.49	0.4	0.89
14	na	31.223	668.60	0.49	0.4	0.89
15	na	30.499	652.80	0.49	0.4	0.89
16	na	27.841	596.10	0.49	0.4	0.89
17	na	28.802	615.80	0.49	0.4	0.89
18	na	28.642	613.10	0.49	0.4	0.89
19	na	27.359	589.40	0.49	0.4	0.89
20	na	29.078	623.30	0.49	0.4	0.89
21	na	29.504	630.60	0.49	0.4	0.89
22	na	28.330	606.70	0.49	0.4	0.89
23	na	26.781	573.30	0.49	0.4	0.89
24	na	31.935	684.10	0.49	0.4	0.89
25	na	29.906	640.30	0.49	0.4	0.89
26	na	30.118	644.70	0.49	0.4	0.89
27	na	30.140	645.30	0.49	0.4	0.89
28	na	30.136	643.90	0.49	0.4	0.89
29	na	28.287	606.40	0.49	0.4	0.89
30	na	29.931	640.60	0.49	0.4	0.89
31	na	29.781	636.60	0.49	0.4	0.89

Totals					Average	0.4	0.89
--------	--	--	--	--	---------	-----	------

RETURN TO: HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: West Treatment Plant		3 Operator: <i>[Signature]</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%	6 Avail Fluor. Ion - 79%	7 Month/Year	August 2022	
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	30.801	668.80	0.49	0.4	0.89	
2	na	32.978	717.00	0.49	0.4	0.89	
3	na	35.844	778.40	0.49	0.4	0.89	
4	na	35.011	759.80	0.49	0.4	0.89	
5	na	39.439	814.90	0.47	0.4	0.87	
6	na	46.227	1,002.30	0.49	0.4	0.89	
7	na	46.521	1,010.30	0.49	0.4	0.89	
8	na	33.095	718.50	0.49	0.4	0.89	
9	na	34.986	758.90	0.49	0.4	0.89	
10	na	40.263	874.40	0.49	0.4	0.89	
11	na	36.880	800.10	0.49	0.4	0.89	
12	na	40.970	889.40	0.49	0.4	0.89	
13	na	48.655	1,055.10	0.49	0.4	0.89	
14	na	48.417	1,050.80	0.49	0.4	0.89	
15	na	29.332	633.60	0.49	0.4	0.89	
16	na	18.392	393.30	0.49	0.4	0.89	
17	na	23.085	494.60	0.49	0.4	0.89	
18	na	29.744	636.40	0.49	0.4	0.89	
19	na	29.575	626.10	0.48	0.4	0.88	
20	na	34.093	728.40	0.49	0.4	0.89	
21	na	36.758	797.10	0.49	0.4	0.89	
22	na	39.049	847.80	0.49	0.4	0.89	
23	na	37.924	823.30	0.49	0.4	0.89	
24	na	40.372	876.30	0.49	0.4	0.89	
25	na	35.359	767.00	0.49	0.4	0.89	
26	na	35.561	771.60	0.49	0.4	0.89	
27	na	34.094	739.60	0.49	0.4	0.89	
28	na	23.747	507.30	0.49	0.4	0.89	
29	na	34.022	736.00	0.49	0.4	0.89	
30	na	38.186	828.00	0.49	0.4	0.89	
31	na	36.731	797.90	0.49	0.4	0.89	
Totals					Average	0.4	0.89

RETURN TO: HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year: September 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L


1	na	38.094	826.60	0.49	0.4	0.89	
2	na	37.084	804.50	0.49	0.4	0.89	
3	na	38.708	840.90	0.49	0.4	0.89	
4	na	33.992	738.60	0.49	0.4	0.89	
5	na	27.064	589.50	0.50	0.4	0.90	
6	na	37.534	815.00	0.49	0.4	0.89	
7	na	38.629	839.10	0.49	0.4	0.89	
8	na	40.096	871.00	0.49	0.4	0.89	
9	na	38.891	843.90	0.49	0.4	0.89	
10	na	17.238	369.10	0.49	0.4	0.89	
11	na	22.853	489.00	0.49	0.4	0.89	
12	na	29.680	633.40	0.49	0.4	0.89	
13	na	33.335	723.10	0.49	0.4	0.89	
14	na	36.739	797.80	0.49	0.4	0.89	
15	na	37.373	812.50	0.49	0.4	0.89	
16	na	34.436	747.80	0.49	0.4	0.89	
17	na	33.788	734.10	0.49	0.4	0.89	
18	na	25.570	557.00	0.50	0.4	0.90	
19	na	35.186	764.00	0.49	0.4	0.89	
20	na	37.262	809.50	0.49	0.4	0.89	
21	na	32.649	709.50	0.49	0.4	0.89	
22	na	30.311	659.80	0.49	0.4	0.89	
23	na	27.394	596.80	0.50	0.4	0.90	
24	na	25.110	548.10	0.50	0.4	0.90	
25	na	28.445	620.40	0.50	0.4	0.90	
26	na	29.397	640.00	0.49	0.4	0.89	
27	na	31.633	687.30	0.49	0.4	0.89	
28	na	32.431	704.90	0.49	0.4	0.89	
29	na	33.718	731.50	0.49	0.4	0.89	
30	na	34.329	746.60	0.49	0.4	0.89	
Totals					Average	0.4	0.89

RETURN TO: HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: East Treatment Plant		3 Operator: <i>[Signature]</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%		6 Avail Fluor. Ion - 79%		
				7 Month/Year September 2022		
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	29.601	634.60	0.49	0.4	0.89	
2	na	29.896	640.00	0.49	0.4	0.89	
3	na	28.851	617.30	0.49	0.4	0.89	
4	na	29.728	636.70	0.49	0.4	0.89	
5	na	29.653	634.80	0.49	0.4	0.89	
6	na	29.600	633.70	0.49	0.4	0.89	
7	na	30.445	651.80	0.49	0.4	0.89	
8	na	29.782	636.80	0.49	0.4	0.89	
9	na	28.957	619.90	0.49	0.4	0.89	
10	na	27.495	589.40	0.49	0.4	0.89	
11	na	22.672	485.20	0.49	0.4	0.89	
12	na	22.668	484.90	0.49	0.4	0.89	
13	na	22.237	475.80	0.49	0.4	0.89	
14	na	23.825	509.00	0.49	0.4	0.89	
15	na	27.362	586.10	0.49	0.4	0.89	
16	na	27.676	591.90	0.49	0.4	0.89	
17	na	28.441	609.50	0.49	0.4	0.89	
18	na	24.794	530.60	0.49	0.4	0.89	
19	na	26.740	572.30	0.49	0.4	0.89	
20	na	25.614	548.20	0.49	0.4	0.89	
21	na	25.876	554.10	0.49	0.4	0.89	
22	na	25.296	541.40	0.49	0.4	0.89	
23	na	25.609	547.80	0.49	0.4	0.89	
24	na	27.129	580.70	0.49	0.4	0.89	
25	na	27.382	586.00	0.49	0.4	0.89	
26	na	28.183	603.50	0.49	0.4	0.89	
27	na	27.377	586.00	0.49	0.4	0.89	
28	na	26.694	571.40	0.49	0.4	0.89	
29	na	26.567	568.70	0.49	0.4	0.89	
30	na	26.630	569.70	0.49	0.4	0.89	
Totals					Average	0.4	0.89

RETURN TO: HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: 
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year October 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride values mg/L

1	na	26.884	575.20	0.49	0.4	0.89	
2	na	26.578	568.80	0.49	0.4	0.89	
3	na	26.187	560.40	0.49	0.4	0.89	
4	na	26.449	566.20	0.49	0.4	0.89	
5	na	25.420	544.00	0.49	0.4	0.89	
6	na	27.045	578.40	0.49	0.4	0.89	
7	na	25.627	548.70	0.49	0.4	0.89	
8	na	25.152	538.30	0.49	0.4	0.89	
9	na	25.350	537.40	0.48	0.4	0.88	
10	na	25.661	548.80	0.49	0.4	0.89	
11	na	26.572	568.90	0.49	0.4	0.89	
12	na	25.330	542.60	0.49	0.4	0.89	
13	na	22.609	483.80	0.49	0.4	0.89	
14	na	22.382	478.80	0.49	0.4	0.89	
15	na	22.525	482.20	0.49	0.4	0.89	
16	na	21.795	465.40	0.49	0.4	0.89	
17	na	21.925	469.50	0.49	0.4	0.89	
18	na	17.831	381.10	0.49	0.4	0.89	
19	na	10.055	266.50	0.60	0.4	1.00	
20	na	13.771	294.10	0.49	0.4	0.89	
21	na	13.838	295.70	0.49	0.4	0.89	
22	na	13.560	289.70	0.49	0.4	0.89	
23	na	15.624	333.50	0.49	0.4	0.89	
24	na	13.888	297.30	0.49	0.4	0.89	
25	na	13.597	290.50	0.49	0.4	0.89	
26	na	13.650	291.60	0.49	0.4	0.89	
27	na	13.643	286.00	0.48	0.4	0.88	
28	na	13.852	284.60	0.47	0.4	0.87	
29	na	13.911	285.80	0.47	0.4	0.87	
30	na	13.467	276.50	0.47	0.4	0.87	
31	na	13.897	281.50	0.46	0.4	0.86	
Totals					Average	0.4	0.89

RETURN TO: HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *Eric C. Lee*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year November 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	21.410	457.90	0.49	0.4	0.89
2	na	23.499	458.50	0.44	0.4	0.84
3	na	19.740	421.80	0.49	0.4	0.89
4	na	14.476	309.30	0.49	0.4	0.89
5	na	14.383	307.10	0.49	0.4	0.89
6	na	16.203	345.60	0.48	0.4	0.88
7	na	20.449	437.80	0.49	0.4	0.89
8	na	18.525	395.50	0.49	0.4	0.89
9	na	14.684	313.80	0.49	0.4	0.89
10	na	17.083	364.80	0.49	0.4	0.89
11	na	14.853	317.50	0.49	0.4	0.89
12	na	14.098	301.30	0.49	0.4	0.89
13	na	12.314	262.60	0.48	0.4	0.88
14	na	14.788	315.50	0.49	0.4	0.89
15	na	15.461	318.90	0.47	0.4	0.87
16	na	16.932	360.00	0.48	0.4	0.88
17	na	15.643	334.00	0.49	0.4	0.89
18	na	15.532	331.60	0.49	0.4	0.89
19	na	16.324	348.80	0.49	0.4	0.89
20	na	15.842	338.40	0.49	0.4	0.89
21	na	15.883	339.30	0.49	0.4	0.89
22	na	16.133	344.60	0.49	0.4	0.89
23	na	15.574	332.90	0.49	0.4	0.89
24	na	15.248	325.40	0.49	0.4	0.89
25	na	12.657	270.60	0.49	0.4	0.89
26	na	12.331	263.10	0.49	0.4	0.89
27	na	12.028	256.40	0.48	0.4	0.88
28	na	15.755	332.50	0.48	0.4	0.88
29	na	14.728	314.50	0.49	0.4	0.89
30	na	15.717	335.60	0.49	0.4	0.89

Totals					Average	0.4	0.88
--------	--	--	--	--	---------	-----	------

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year November 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	13.587	279.00	0.47	0.4	0.87
2	na	13.586	254.40	0.43	0.4	0.83
3	na	13.851	284.40	0.47	0.4	0.87
4	na	13.251	272.00	0.47	0.4	0.87
5	na	13.424	275.60	0.47	0.4	0.87
6	na	13.910	285.60	0.47	0.4	0.87
7	na	13.307	273.20	0.47	0.4	0.87
8	na	13.277	272.60	0.47	0.4	0.87
9	na	13.665	280.60	0.47	0.4	0.87
10	na	13.092	268.80	0.47	0.4	0.87
11	na	13.265	272.30	0.47	0.4	0.87
12	na	13.379	274.60	0.47	0.4	0.87
13	na	13.578	278.70	0.47	0.4	0.87
14	na	13.570	278.60	0.47	0.4	0.87
15	na	12.847	268.90	0.48	0.4	0.88
16	na	13.570	278.60	0.47	0.4	0.87
17	na	13.431	275.80	0.47	0.4	0.87
18	na	13.524	277.60	0.47	0.4	0.87
19	na	13.499	277.10	0.47	0.4	0.87
20	na	12.767	262.20	0.47	0.4	0.87
21	na	11.869	243.50	0.47	0.4	0.87
22	na	11.644	238.90	0.47	0.4	0.87
23	na	11.897	244.10	0.47	0.4	0.87
24	na	11.990	245.90	0.47	0.4	0.87
25	na	12.184	250.10	0.47	0.4	0.87
26	na	12.494	256.40	0.47	0.4	0.87
27	na	12.475	256.00	0.47	0.4	0.87
28	na	12.464	252.80	0.46	0.4	0.86
29	na	12.449	255.50	0.47	0.4	0.87
30	na	12.440	255.30	0.47	0.4	0.87

Totals					Average	0.4	0.87
--------	--	--	--	--	---------	-----	------

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SIF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year December 2022

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	12.403	254.60	0.47	0.4	0.87
2	na	13.292	272.80	0.47	0.4	0.87
3	na	12.984	266.50	0.47	0.4	0.87
4	na	12.927	265.40	0.47	0.4	0.87
5	na	7.210	249.10	0.47	0.4	0.87
6	na	0.000	0.00		0.4	
7	na	5.036	224.20	0.47	0.4	0.87
8	na	13.778	282.90	0.47	0.4	0.87
9	na	13.724	281.80	0.47	0.4	0.87
10	na	13.700	281.30	0.47	0.4	0.87
11	na	13.681	280.80	0.47	0.4	0.87
12	na	13.668	280.60	0.47	0.4	0.87
13	na	13.656	280.40	0.47	0.4	0.87
14	na	8.102	248.80	0.47	0.4	0.87
15	na	12.714	260.90	0.47	0.4	0.87
16	na	12.622	259.10	0.47	0.4	0.87
17	na	12.693	260.30	0.47	0.4	0.87
18	na	13.914	285.80	0.47	0.4	0.87
19	na	13.439	275.90	0.47	0.4	0.87
20	na	14.857	305.00	0.47	0.4	0.87
21	na	20.677	425.40	0.47	0.4	0.87
22	na	14.379	295.10	0.47	0.4	0.87
23	na	12.073	247.70	0.47	0.4	0.87
24	na	12.092	248.10	0.47	0.4	0.87
25	na	12.113	248.60	0.47	0.4	0.87
26	na	11.982	245.90	0.47	0.4	0.87
27	na	20.998	431.90	0.47	0.4	0.87
28	na	29.806	616.30	0.47	0.4	0.87
29	na	29.743	636.50	0.49	0.4	0.89
30	na	29.641	634.40	0.49	0.4	0.89
31	na	27.818	594.30	0.49	0.4	0.89

Totals				Average	0.4	0.87
--------	--	--	--	---------	-----	------

RETURN TO: HHS - REGULATION AND LICENSURE
 East plant taken off-line the afternoon of 12/5/22 through the afternoon of 12/7/22E. Lee
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: West Treatment Plant		3 Operator: <i>Eric Lee</i>		
4 Fluor. Chem. Used: H2SIF6		5 Purity - 24%		6 Avail Fluor. Ion - 79%		
				7 Month/Year December 2022		
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	15.763	336.80	0.49	0.4	0.89
2	na	15.413	329.10	0.49	0.4	0.89
3	na	14.840	317.10	0.49	0.4	0.89
4	na	12.222	261.00	0.49	0.4	0.89
5	na	19.849	427.82	0.49	0.4	0.89
6	na	25.353	546.45	0.49	0.4	0.89
7	na	22.724	489.79	0.49	0.4	0.89
8	na	16.458	351.90	0.49	0.4	0.89
9	na	14.763	315.10	0.49	0.4	0.89
10	na	15.876	338.80	0.49	0.4	0.89
11	na	11.374	243.50	0.49	0.4	0.89
12	na	14.335	305.40	0.49	0.4	0.89
13	na	15.713	336.10	0.49	0.4	0.89
14	na	18.071	389.50	0.49	0.4	0.89
15	na	17.511	373.50	0.49	0.4	0.89
16	na	16.320	348.80	0.49	0.4	0.89
17	na	13.621	291.00	0.49	0.4	0.89
18	na	13.367	285.40	0.49	0.4	0.89
19	na	14.332	305.90	0.49	0.4	0.89
20	na	16.233	346.40	0.49	0.4	0.89
21	na	15.994	342.00	0.49	0.4	0.89
22	na	15.014	320.90	0.49	0.4	0.89
23	na	12.462	266.00	0.49	0.4	0.89
24	na	12.746	271.90	0.49	0.4	0.89
25	na	12.655	270.10	0.49	0.4	0.89
26	na	12.924	275.80	0.49	0.4	0.89
27	na	6.940	148.00	0.49	0.4	0.89
28	na	0.000	0.00		0.4	
29	na	0.000	0.00		0.4	
30	na	0.000	0.00		0.4	
31	na	0.000	0.00		0.4	
Totals				Average	0.4	0.89

West Plant taken off-line the afternoon of 12/27/22 E. Lee RETURN TO:

HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System		2 Point of Ap: East Treatment Plant		3 Operator: <i>[Signature]</i>		
4 Fluor. Chem. Used: H2SiF6		5 Purity - 24%	6 Avail Fluor. Ion - 79%	7 Month/Year	January 2023	
8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	26.174	559.80	0.49	0.4	0.89
2	na	26.741	572.10	0.49	0.4	0.89
3	na	28.142	603.10	0.49	0.4	0.89
4	na	28.198	603.20	0.49	0.4	0.89
5	na	27.968	597.30	0.49	0.4	0.89
6	na	28.690	614.80	0.49	0.4	0.89
7	na	29.312	626.20	0.49	0.4	0.89
8	na	27.035	578.30	0.49	0.4	0.89
9	na	27.417	586.60	0.49	0.4	0.89
10	na	27.845	596.40	0.49	0.4	0.89
11	na	28.724	613.70	0.49	0.4	0.89
12	na	29.962	641.90	0.49	0.4	0.89
13	na	30.531	653.10	0.49	0.4	0.89
14	na	29.653	634.50	0.49	0.4	0.89
15	na	28.915	617.70	0.49	0.4	0.89
16	na	27.211	582.20	0.49	0.4	0.89
17	na	26.910	575.80	0.49	0.4	0.89
18	na	29.295	626.80	0.49	0.4	0.89
19	na	29.257	625.80	0.49	0.4	0.89
20	na	26.789	572.90	0.49	0.4	0.89
21	na	26.719	571.50	0.49	0.4	0.89
22	na	26.768	572.50	0.49	0.4	0.89
23	na	26.718	571.60	0.49	0.4	0.89
24	na	27.551	589.30	0.49	0.4	0.89
25	na	28.612	612.90	0.49	0.4	0.89
26	na	30.056	642.80	0.49	0.4	0.89
27	na	30.368	649.80	0.49	0.4	0.89
28	na	28.550	611.00	0.49	0.4	0.89
29	na	27.112	579.10	0.49	0.4	0.89
30	na	28.536	611.10	0.49	0.4	0.89
31	na	30.322	648.80	0.49	0.4	0.89
Totals				Average	0.4	0.89

RETURN TO: HHS - REGULATION AND LICENSURE
P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year January 2023

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	0.000	0.00		0.4		
2	na	0.000	0.00		0.4		
3	na	0.000	0.00		0.4		
4	na	0.000	0.00		0.4		
5	na	0.000	0.00		0.4		
6	na	0.000	0.00		0.4		
7	na	0.000	0.00		0.4		
8	na	0.000	0.00		0.4		
9	na	0.000	0.00		0.4		
10	na	0.000	0.00		0.4		
11	na	0.000	0.00		0.4		
12	na	0.000	0.00		0.4		
13	na	0.000	0.00		0.4		
14	na	0.000	0.00		0.4		
15	na	0.000	0.00		0.4		
16	na	0.000	0.00		0.4		
17	na	0.000	0.00		0.4		
18	na	0.000	0.00		0.4		
19	na	0.000	0.00		0.4		
20	na	0.000	0.00		0.4		
21	na	0.000	0.00		0.4		
22	na	0.000	0.00		0.4		
23	na	0.000	0.00		0.4		
24	na	0.000	0.00		0.4		
25	na	0.000	0.00		0.4		
26	na	0.000	0.00		0.4		
27	na	0.000	0.00		0.4		
28	na	0.000	0.00		0.4		
29	na	0.000	0.00		0.4		
30	na	0.000	0.00		0.4		
31	na	0.000	0.00		0.4		
Totals					Average	0.4	

West Plant Out Of Service
 All of January. E.Lee 2/6/23

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *Eric Joe*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year February 2023

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Treated Water Tests mg/L

1	na	0.000	0.00		0.4	
2	na	0.000	0.00		0.4	
3	na	0.000	0.00		0.4	
4	na	0.000	0.00		0.4	
5	na	0.000	0.00		0.4	
6	na	0.000	0.00		0.4	
7	na	0.000	0.00		0.4	
8	na	0.000	0.00		0.4	
9	na	0.000	0.00		0.4	
10	na	0.000	0.00		0.4	
11	na	0.000	0.00		0.4	
12	na	0.000	0.00		0.4	
13	na	0.000	0.00		0.4	
14	na	0.000	0.00		0.4	
15	na	0.000	0.00		0.4	
16	na	0.000	0.00		0.4	
17	na	0.000	0.00		0.4	
18	na	0.000	0.00		0.4	
19	na	0.000	0.00		0.4	
20	na	0.000	0.00		0.4	
21	na	0.000	0.00		0.4	
22	na	0.000	0.00		0.4	
23	na	0.000	0.00		0.4	
24	na	0.000	0.00		0.4	
25	na	0.000	0.00		0.4	
26	na	0.000	0.00		0.4	
27	na	0.000	0.00		0.4	
28	na	0.000	0.00		0.4	
Totals					Average	0.4

RETURN TO:
 West Plant Out Of Service all of February E. Lee 3/2/23

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SIF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year February 2023

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	30.437	651.30	0.49	0.4	0.89	
2	na	27.829	594.60	0.49	0.4	0.89	
3	na	26.528	567.50	0.49	0.4	0.89	
4	na	28.446	609.10	0.49	0.4	0.89	
5	na	27.910	596.40	0.49	0.4	0.89	
6	na	27.583	590.90	0.49	0.4	0.89	
7	na	28.552	610.90	0.49	0.4	0.89	
8	na	29.344	627.60	0.49	0.4	0.89	
9	na	30.587	654.40	0.49	0.4	0.89	
10	na	28.886	618.30	0.49	0.4	0.89	
11	na	28.475	608.10	0.49	0.4	0.89	
12	na	28.317	605.90	0.49	0.4	0.89	
13	na	28.021	600.40	0.49	0.4	0.89	
14	na	28.569	611.20	0.49	0.4	0.89	
15	na	27.951	597.10	0.49	0.4	0.89	
16	na	27.874	596.30	0.49	0.4	0.89	
17	na	27.682	592.20	0.49	0.4	0.89	
18	na	27.988	598.60	0.49	0.4	0.89	
19	na	27.847	595.80	0.49	0.4	0.89	
20	na	28.372	607.80	0.49	0.4	0.89	
21	na	29.420	629.40	0.49	0.4	0.89	
22	na	29.491	631.40	0.49	0.4	0.89	
23	na	29.312	627.50	0.49	0.4	0.89	
24	na	26.866	574.00	0.49	0.4	0.89	
25	na	27.225	582.50	0.49	0.4	0.89	
26	na	28.325	607.20	0.49	0.4	0.89	
27	na	29.635	634.10	0.49	0.4	0.89	
28	na	26.046	550.00	0.48	0.4	0.88	
Totals					Average	0.4	0.89

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year March 2023

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	29.788	637.40	0.49	0.4	0.89	
2	na	29.076	621.30	0.49	0.4	0.89	
3	na	26.975	578.40	0.49	0.4	0.89	
4	na	27.752	592.80	0.49	0.4	0.89	
5	na	28.473	610.10	0.49	0.4	0.89	
6	na	28.145	602.50	0.49	0.4	0.89	
7	na	29.583	632.90	0.49	0.4	0.89	
8	na	28.501	609.80	0.49	0.4	0.89	
9	na	28.205	603.40	0.49	0.4	0.89	
10	na	26.107	550.10	0.48	0.4	0.88	
11	na	29.528	631.80	0.49	0.4	0.89	
12	na	27.205	582.30	0.49	0.4	0.89	
13	na	28.182	602.10	0.49	0.4	0.89	
14	na	28.141	602.20	0.49	0.4	0.89	
15	na	28.553	611.90	0.49	0.4	0.89	
16	na	29.024	621.30	0.49	0.4	0.89	
17	na	27.397	585.40	0.49	0.4	0.89	
18	na	27.059	579.80	0.49	0.4	0.89	
19	na	27.786	593.40	0.49	0.4	0.89	
20	na	27.729	594.20	0.49	0.4	0.89	
21	na	28.444	607.50	0.49	0.4	0.89	
22	na	24.173	518.10	0.49	0.4	0.89	
23	na	15.815	337.60	0.49	0.4	0.89	
24	na	14.073	300.60	0.49	0.4	0.89	
25	na	14.373	307.00	0.49	0.4	0.89	
26	na	13.987	298.80	0.49	0.4	0.89	
27	na	14.873	317.40	0.49	0.4	0.89	
28	na	20.151	430.90	0.49	0.4	0.89	
29	na	15.204	325.30	0.49	0.4	0.89	
30	na	13.246	283.00	0.49	0.4	0.89	
31	na	14.520	309.80	0.49	0.4	0.89	
Totals					Average	0.4	0.89

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year March 2023

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	0.000	0.00		0.4		
2	na	0.000	0.00		0.4		
3	na	0.000	0.00		0.4		
4	na	0.000	0.00		0.4		
5	na	0.000	0.00		0.4		
6	na	0.000	0.00		0.4		
7	na	0.000	0.00		0.4		
8	na	0.000	0.00		0.4		
9	na	0.000	0.00		0.4		
10	na	0.000	0.00		0.4		
11	na	0.000	0.00		0.4		
12	na	0.000	0.00		0.4		
13	na	0.000	0.00		0.4		
14	na	0.000	0.00		0.4		
15	na	0.000	0.00		0.4		
16	na	0.000	0.00		0.4		
17	na	0.000	0.00		0.4		
18	na	0.000	0.00		0.4		
19	na	0.000	0.00		0.4		
20	na	0.000	0.00		0.4		
21	na	0.000	0.00		0.4		
22	na	4.585	98.50	0.49	0.4	0.89	
23	na	12.795	281.30	0.50	0.4	0.90	
24	na	16.047	352.10	0.50	0.4	0.90	
25	na	12.143	266.60	0.50	0.4	0.90	
26	na	11.675	255.50	0.50	0.4	0.90	
27	na	13.122	287.10	0.50	0.4	0.90	
28	na	15.676	344.10	0.50	0.4	0.90	
29	na	11.682	255.00	0.50	0.4	0.90	
30	na	13.911	304.80	0.50	0.4	0.90	
31	na	12.557	274.40	0.50	0.4	0.90	
Totals					Average	0.4	0.90

West plant placed in service the afternoon of 3/22/23 E. Lee

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *E. H. Stager*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year April 2023

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	9.282	204.10	0.50	0.4	0.90	
2	na	10.499	229.40	0.50	0.4	0.90	
3	na	14.982	328.60	0.50	0.4	0.90	
4	na	14.597	307.90	0.48	0.4	0.88	
5	na	15.113	331.50	0.50	0.4	0.90	
6	na	13.985	307.00	0.50	0.4	0.90	
7	na	13.973	306.40	0.50	0.4	0.90	
8	na	19.529	426.80	0.50	0.4	0.90	
9	na	23.566	514.00	0.50	0.4	0.90	
10	na	21.276	463.90	0.50	0.4	0.90	
11	na	22.811	497.90	0.50	0.4	0.90	
12	na	25.094	547.00	0.50	0.4	0.90	
13	na	25.111	547.60	0.50	0.4	0.90	
14	na	24.869	543.30	0.50	0.4	0.90	
15	na	15.106	330.90	0.50	0.4	0.90	
16	na	14.012	307.50	0.50	0.4	0.90	
17	na	13.860	304.10	0.50	0.4	0.90	
18	na	13.808	302.90	0.50	0.4	0.90	
19	na	16.133	353.80	0.50	0.4	0.90	
20	na	22.386	490.10	0.50	0.4	0.90	
21	na	20.371	445.80	0.50	0.4	0.90	
22	na	15.326	335.40	0.50	0.4	0.90	
23	na	13.629	298.80	0.50	0.4	0.90	
24	na	16.683	366.90	0.50	0.4	0.90	
25	na	16.429	359.90	0.50	0.4	0.90	
26	na	16.443	360.50	0.50	0.4	0.90	
27	na	18.119	397.80	0.50	0.4	0.90	
28	na	17.070	375.10	0.50	0.4	0.90	
29	na	15.413	337.50	0.50	0.4	0.90	
30	na	17.619	387.60	0.50	0.4	0.90	
Totals					Average	0.4	0.90

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: West Treatment Plant 3 Operator: *Bud Lee*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year May 2023

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Treated Water Tests mg/L

1	na	18.951	416.10	0.50	0.4	0.90	
2	na	19.404	425.80	0.50	0.4	0.90	
3	na	23.524	513.50	0.50	0.4	0.90	
4	na	29.667	646.50	0.50	0.4	0.90	
5	na	28.647	622.60	0.49	0.4	0.89	
6	na	23.055	502.80	0.50	0.4	0.90	
7	na	23.222	506.10	0.50	0.4	0.90	
8	na	24.820	541.90	0.50	0.4	0.90	
9	na	26.255	572.40	0.50	0.4	0.90	
10	na	27.865	607.50	0.50	0.4	0.90	
11	na	27.910	608.90	0.50	0.4	0.90	
12	na	27.324	595.50	0.50	0.4	0.90	
13	na	24.598	537.50	0.50	0.4	0.90	
14	na	22.718	496.60	0.50	0.4	0.90	
15	na	32.183	693.67	0.49	0.4	0.89	
16	na	41.035	884.46	0.49	0.4	0.89	
17	na	52.808	1,138.21	0.49	0.4	0.89	
18	na	54.682	1,178.60	0.49	0.4	0.89	
19	na	55.070	1,186.97	0.49	0.4	0.89	
20	na	43.715	942.22	0.49	0.4	0.89	
21	na	34.167	741.80	0.49	0.4	0.89	
22	na	39.808	864.10	0.49	0.4	0.89	
23	na	42.266	916.50	0.49	0.4	0.89	
24	na	41.436	899.10	0.49	0.4	0.89	
25	na	38.504	835.00	0.49	0.4	0.89	
26	na	34.913	759.10	0.49	0.4	0.89	
27	na	38.254	829.80	0.49	0.4	0.89	
28	na	36.532	792.90	0.49	0.4	0.89	
29	na	36.843	799.30	0.49	0.4	0.89	
30	na	41.493	900.10	0.49	0.4	0.89	
31	na	41.431	898.40	0.49	0.4	0.89	
Totals					Average	0.4	0.89

RETURN TO: HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year May 2023

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	25.557	546.10	0.49	0.4	0.89	
2	na	26.997	577.50	0.49	0.4	0.89	
3	na	24.730	529.10	0.49	0.4	0.89	
4	na	24.873	531.90	0.49	0.4	0.89	
5	na	24.438	523.00	0.49	0.4	0.89	
6	na	23.291	497.70	0.49	0.4	0.89	
7	na	25.897	553.80	0.49	0.4	0.89	
8	na	25.796	551.80	0.49	0.4	0.89	
9	na	24.771	529.90	0.49	0.4	0.89	
10	na	23.740	507.80	0.49	0.4	0.89	
11	na	23.127	494.60	0.49	0.4	0.89	
12	na	23.034	492.50	0.49	0.4	0.89	
13	na	23.025	492.30	0.49	0.4	0.89	
14	na	22.987	491.60	0.49	0.4	0.89	
15	na	10.225	220.39	0.49	0.4	0.89	
16	na	0.000	0.00		0.4		
17	na	0.000	0.00		0.4		
18	na	0.000	0.00		0.4		
19	na	0.000	0.00		0.4		
20	na	12.191	262.76	0.49	0.4	0.89	
21	na	26.591	569.00	0.49	0.4	0.89	
22	na	27.233	582.80	0.49	0.4	0.89	
23	na	27.176	581.60	0.49	0.4	0.89	
24	na	27.156	581.10	0.49	0.4	0.89	
25	na	27.143	586.10	0.49	0.4	0.89	
26	na	27.048	590.10	0.50	0.4	0.90	
27	na	26.367	575.40	0.50	0.4	0.90	
28	na	25.724	560.90	0.50	0.4	0.90	
29	na	27.000	589.00	0.50	0.4	0.90	
30	na	26.887	586.50	0.50	0.4	0.90	
31	na	27.167	592.40	0.50	0.4	0.90	
Totals					Average	0.4	0.89

East Plant off-line a.m. of May 15 through a.m. of May 20 E. Lee

RETURN TO: HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007

1 Name of PWS: Lincoln Water System 2 Point of Ap: East Treatment Plant 3 Operator: *[Signature]*
 4 Fluor. Chem. Used: H2SiF6 5 Purity - 24% 6 Avail Fluor. Ion - 79% 7 Month/Year June 2023

8	9	10	11	**12	13	14
Date	Meter Reading	Millions Gallons Treated	Pounds of Chemical Added	mg/L Added = lbs x % purity x % Fluor. Ion / 8.34 / MG	Average Natural Fluoride	Calculated Fluoride Values mg/L

1	na	24.808	541.80	0.50	0.4	0.90	
2	na	22.740	495.60	0.50	0.4	0.90	
3	na	23.406	510.30	0.50	0.4	0.90	
4	na	22.832	498.10	0.50	0.4	0.90	
5	na	22.564	491.80	0.50	0.4	0.90	
6	na	23.023	501.90	0.50	0.4	0.90	
7	na	25.254	550.30	0.50	0.4	0.90	
8	na	28.192	616.10	0.50	0.4	0.90	
9	na	28.832	628.50	0.50	0.4	0.90	
10	na	28.680	624.60	0.50	0.4	0.90	
11	na	24.091	525.50	0.50	0.4	0.90	
12	na	25.941	565.20	0.50	0.4	0.90	
13	na	26.182	570.80	0.50	0.4	0.90	
14	na	26.004	567.60	0.50	0.4	0.90	
15	na	28.649	624.70	0.50	0.4	0.90	
16	na	29.689	647.50	0.50	0.4	0.90	
17	na	28.579	622.20	0.49	0.4	0.89	
18	na	27.789	606.60	0.50	0.4	0.90	
19	na	33.001	719.30	0.50	0.4	0.90	
20	na	35.993	785.10	0.50	0.4	0.90	
21	na	44.178	963.90	0.50	0.4	0.90	
22	na	46.530	1,016.40	0.50	0.4	0.90	
23	na	46.698	1,018.10	0.50	0.4	0.90	
24	na	47.673	1,040.70	0.50	0.4	0.90	
25	na	43.416	946.90	0.50	0.4	0.90	
26	na	42.285	923.60	0.50	0.4	0.90	
27	na	40.036	873.50	0.50	0.4	0.90	
28	na	41.810	912.60	0.50	0.4	0.90	
29	na	39.699	865.50	0.50	0.4	0.90	
30	na	35.886	782.60	0.50	0.4	0.90	
Totals					Average	0.4	0.90

RETURN TO:

HHS - REGULATION AND LICENSURE
 P.O. BOX 95007 - 301 CENTENNIAL MALL SOUTH
 LINCOLN, NE 68509 - 5007